

Memo

Regarding Treasurer's proposed build out, 3rd floor, East End

I see no code violations or readily identifiable safety issues with the proposed remodel, so long as required signage, such as "EXIT" signage are properly moved and updated with the remodel.

However, I recommend that the door from the breakroom to the main 3rd floor hallway be retained for exit egress.

Bradley Hermes
Safety Program Manager
Oklahoma County